

## El. specifikation för golv och mellanbjälklags linjer

<b>Golvblocklinjen:</b>					
<b>Station 1. Underrede</b>		El. uttag, 4 st			
Station 1. Spikportal		Portal	1,1 kw	1 fas frek	20A
		Verktygsvagn 1.	0,55kw	1 fas frek	10A
		Verktygsvagn 2.	0,55kw	1 fas frek	10A
		Sågmotor	4 kw		8,5A
<b>Station 2 - 3. Vändare</b>		Hydraulikaggregat	7,5kw	15,5A (35A)	
		Vagn	0,75kw	2A (4A)	
<b>Station 3. Underrede</b>		El. uttag, 4 st		2 x 230VAC, (10A) + N + PE	
<b>Mellanbjälklagslinje:</b>				3 x 400VAC, (35A) + N + PE	
<b>Station 1. Underrede</b>		El. uttag, 4 st		2 x 230VAC, (10A) + N + PE	
<b>Station 1. Portal</b>		Portal	1,1kw	1 fas frek	20A
<b>Station 1 - 2.</b>		Hydraulikaggregat	7,5kw	15,5A (35A)	
		Vagn	0,75kw	2A (4A)	
<b>Station 2. Portal</b>		Portal	1,1kw	1 fas frek	20A
		Verktygsvagn 1.	0,55kw	1 fas frek	10A
		Verktygsvagn 2.	0,55kw	1 fas frek	10A
		Sågmotor	4 kw		8,5A (20A)
3 x 400VAC, (35A) + N + PE					